

| | | | |
|--------------|-----------------------|---------------|-----------------|
| Originator | : CHARLES CHAMBERLAIN | Schedule Date | : |
| Planner | : RANDY UTLEY | Priority | : 3A |
| Drawing No | : 1SCA-M2056A | Clearance | : YES |
| Equip No/Cat | : 1SCA--0 8 | Tag Request | : |
| Project ID | : 1SCA-FAN-44 | Text ID | : |
| Shutdown | : N No Shutdown | Frequency | : NOT SCHEDULED |
| Ref No | : | Last Reading | : No Reading |

Date Completed: _____ Failure Code: _____

Completed By : _____ Signature : _____

Accepted By : _____ Signature : _____

| Step | Job Scope | MN | DY | Safety and Additional Information |
|------|--|----|----|--|
| 1 | RETROFIT BOILER VENT FAN 44 AND DUCT WORK IMPACTED BY OVERFIRE AIR MODIFICATION ***** ADDITIONAL INFORMATION: A. CONTROLS AND TEMPERATURE TRANSMITTER STAGED FOR THIS WORKORDER ***** JOB SCOPE: 1. REINSTALL VENTILATION SYSTEM | 2 | 1 | ***** SAFETY / ENVIRONMENTAL REQUIREMENTS: A. ALWAYS WEAR THE REQUIRED PPE. B. SIGN ON APPROPRIATE CLEARANCE C. WATCH FOR CONTRACTORS WORKING IN THE AREA |

[illegible]

**** IMPORTANT NOTICE ****

YOU ARE RESPONSIBLE FOR YOUR OWN SAFETY AND MUST ENSURE THAT THE REQUIRED PPE IS WORN FOR EVERY JOB YOU ARE DOING. IF YOU HAVE ANY QUESTIONS CONCERNING THE WORK RULES, SAFETY CODES, OR REQUIRED PPE, PLEASE CONTACT YOUR SUPERVISOR.

Job Feedback/Historical Notes:



IP7_037379

** Work Order Parts List **

| Part No | Description | PO/Req/SIR | Date Due | U/M | Reqd | Commit | Issued/Rcvd | |
|---------|-------------|--|-----------|----------|------|--------|-------------|----|
| 1 | 05522 | TERMINAL, 1 HOLE LUG | S 248084 | 05/01/03 | EA | 3 | 0 | 3 |
| 2 | 05523 | TERMINAL, 1 HOLE LUG | S 248084 | 05/01/03 | EA | 12 | 0 | 12 |
| 3 | 29494 | TRANSMITTER, TEMPERATURE | S 244396 | 03/25/03 | EA | 1 | 0 | 1 |
| 4 | 30552 | COMPOUND, SEALANT | S 244493 | 03/25/03 | EA | 6 | 0 | 6 |
| 5 | 34946 | FITTING, COPPER SOLDER | S 248191* | 05/02/03 | EA | 20 | 0 | 20 |
| 6 | 34960 | FITTING, COPPER SOLDER | S 248191 | 05/02/03 | EA | 20 | 0 | 20 |
| 7 | 50200 | BOX, JUNCTION | S 247904 | 04/29/03 | EA | 1 | 0 | 1 |
| 8 | 51243 | FITTING, BRASS CONNECTOR | S 248442 | 05/06/03 | EA | 0 | 0 | 0 |
| 9 | 51271 | FITTING, BRASS CONNECTOR | S 248442 | 05/06/03 | EA | 2 | 0 | 2 |
| 10 | 54203 | BANDING, MATERIAL | S 244493 | 03/25/03 | RL | 1 | 0 | 1 |
| 11 | 58397 | CONDUIT, RIGID | S 248002 | 04/30/03 | PC | 1 | 0 | 1 |
| 12 | 62221 | SWITCH, DIFF.PRESSURE | S 244397 | 04/01/03 | EA | 1 | 0 | 1 |
| 13 | DIRECT | TUBE, SENSING, AIR FLOW, JOHNSON CONTROLS P/N FTG18A600R | 03-32213 | 04/01/03 | EA | 1 | 0 | 1 |